



OFFICE OF:  
PUBLIC WORKS DEPARTMENT  
WATER POLLUTION CONTROL PLANT  
(712) 328-4642

February 22, 2006

Ms. Jessica Wilcox  
Service Line, Inc.  
2320 Zinga Drive  
Reedsburg, WI 53959

Dear Ms. Wilcox:

The City of Council Bluffs Water Pollution Control Division has reviewed your request for approval to discharge spent wash water from your Renegade parts washer to the sanitary sewer. We do hereby grant approval for such discharge provided the discharged wastewater meets City Ordinance limits for the following pollutants:

Pollutant	Concentration Limit	Pollutant	Concentration Limit
Arsenic	0.10 mg/l	Mercury	0.04 mg/l
Cadmium	0.0045 mg/l	Nickel	1.37 mg/l
Chromium	3.88 mg/l	Zinc	4.60 mg/l
Copper	2.80 mg/l	5 day Biochemical Oxygen Demand	350 mg/l
Cyanide	2.10 mg/l	Suspended Solids	350 mg/l
Lead	4.10 mg/l	Oil and Grease	100 mg/l

Please provide us with sample data for these pollutants from the Council Bluffs installation once the washer has operated for a 90 day period to verify compliance.

Sincerely,

Hank Pangelina  
Superintendent, Water Pollution Control  
City of Council Bluffs, Iowa

CITY OF COUNCIL BLUFFS, IOWA - 209 PEARL STREET - 51503-4270  
FAX: (712) 366-4811



"An Equal Opportunity Employer"