



P.O. Box 1567 / Hutchinson, KS 67504-1567

Telephone: 620-694-2685

FAX: 620-694-2604

Office Of: MILLIE REED

May 19, 2006

Ms. Jessica Wilcox
Service Line, Inc.
2320 Zinga Drive
Reedsburg, WI 53959

Dear Ms. Wilcox

I have reviewed the information you furnished regarding possible discharge of spent Renegade parts washer solution to the City of Hutchinson sewer system. Based on my review and on the data submitted, it appears that the parts washer discharge would probably be acceptable at the frequency and in the amount indicated. The City does require Significant Industrial Users to obtain an Industrial Wastewater Discharge permit based on EPA determination criteria. Whether or not your potential client would have to do so would depend upon their responses to an industrial Wastewater Questionnaire.

Whether or not an industry is permitted, all discharges must comply with Sewer Use Ordinance requirements and limits, and the parts washer discharge would need to meet the following local limits:

As (T) .056 mg/L
Cu (T) 1.189 mg/L
CN- (T) 0.295 mg/L
Pb (T) 0.69 mg/L
Zn (T) 3.19 mg/L

Analysis prior to discharge would be required.

If your prospective customer does indeed decide to use a Renegade parts washer with the inherent likelihood of discharge of the contents, they will need to contact my office in order to obtain an Industrial Wastewater Survey prior to discharge. If they are already one of our permitted industries, they will need to notify us of this change in discharge.

If you have any questions or if I can be of further assistance, please feel free to contact me.

Sincerely,

Millie Reed
Wastewater Superintendent



recycled and recyclable

City Hall Fax 620-694-2673
Central Purchasing Fax 620-694-1971
Fire Fax 620-694-2875

Park Fax 620-694-2676
Inspection Fax 620-694-2691
Municipal Court Fax 620-694-2858

Police Fax 620-694-2859
Public Works Fax 620-694-1980
Waste Water Plant Fax 620-694-2604