



CITY OF LARAMIE
PUBLIC WORKS-Wastewater Treatment Plant
P.O. Box C
Laramie, WY 82073

Public Works 721-5230
Solid Waste Division 721-5279
Engineering Division 721-5230
Streets Division 721-5277
Utility Division 721-5280
Wastewater Treatment Plant 721-5204
FAX (307) 721-3077
TDD (307) 721-5295

Wednesday, May 10, 2006

To Whom It May Concern:

I have read a description of the Renegade parts washer built by Service Line Inc. and reviewed analytical data supplied by the company. It appears that the waste from this washer would be acceptable to the Laramie WWTP. However, all wastes discharged by any user of our system must comply with our local limits. Any initial discharge would have to be sampled to show compliance. Further discharges would be accepted without sampling as long as there are no changes to the process.

All dischargers are subject to the possibility of random sampling or permitting according to our standard procedures. The use of the Renegade parts washer alone is unlikely to be a determining factor in the decision on permitting.

The City of Laramie does not endorse any particular product.

Any person who has questions about discharges to our WWTP should feel free to contact the Pretreatment Coordinator.

Oliver Chilson
Industrial Pretreatment Coordinator
City of Laramie