



Mayor Teresa Ann Isaac
LEXINGTON-FAYETTE URBAN COUNTY GOVERNMENT
Division of Sanitary Sewers

May 17, 2006

Ms Jessica Wilcox
Service Line, Inc.
2320 Zinga Drive
Reedsburg, WI 53959


Dear Ms Wilcox

I have reviewed the information submitted regarding the discharge parts washer water to the sanitary sewer. The analytical results submitted do meet our limits for both plants but the results did not include analysis for zinc and copper. In addition we believe that these results may not be typical of all locations. Individual results will depend on the parts being washed and the makeup of the material being washed from the parts.

Any facility discharging industrial process water will need to perform analysis of wastewater from their facility to demonstrate compliance with local regulatory limit. In addition, all facilities discharging industrial wastewater should be evaluated for the need to obtain an industrial discharge permit. The application for industrial discharge permit and additional information can be found at:
<http://www.lfucg.com/PubWorks/SanSewers/IndustrialPretreatment.asp>
Most small facilities are not permitted but many are randomly inspected or sampled to evaluate compliance.

Should you have any additional questions please contact me at 859-425-2412 or by email at richard@lfucg.com.

Regards,


Richard Lamey
Pretreatment Manager

HORSE CAPITAL OF THE WORLD